



Ronald G. Rios  
*Freeholder Director*

Charles E. Tomaro  
*Deputy Director*

Kenneth Armwood  
Charles Kenny  
Leslie Koppel  
Shanti Narra  
Blanquita B. Valenti  
*Freeholders*

Shanti Narra  
*Chairperson, Public Safety and Health  
Committee*

John A. Pulomena  
*County Administrator*

Joseph W. Krisza  
*Department Head*

Michael Gallagher  
*Fire Marshal*

**COUNTY OF MIDDLESEX  
DEPARTMENT OF PUBLIC SAFETY AND HEALTH**

**Division of the Fire Marshal**

**DATE:** 01/03/2019 2<sup>nd</sup>. Review 09/12/2018 – 1<sup>st</sup>. Review  
**TO:** Borough of Middlesex Planning Board  
**FROM:** William Johnson, Deputy Fire Marshal, Middlesex County FM Office  
**RE:** Application # P2018-02  
Location: 930 Lincoln Blvd.  
Block: 249 Lot: 1 & 2

On behalf of the Middlesex County Fire Marshals Office, I have reviewed the above referenced plans and provide the following comments and concerns regarding the same.

**AS OF THIS TIME, NONE OF THE BELOW REQUEST HAVE BEEN ANSWERED OR ADDED TO THE PLANS. AT THIS TIME THE FIRE MARSHALS OFFICE DENY'S THESE PLANS.**

1. Is the building sprinklered? If so have a density report done that the system can handle the change of use.
2. Have fire hydrants to yard and show on drawings.
3. Have fire lanes and signs added to all non-parking areas.
4. Have knox box installed at main entrances.

If you have any questions or need any additional information, please feel free to contact the Middlesex County Fire Marshals Office. 732-316-7194