



Ronald G. Rios  
*Freeholder Director*

Charles E. Tomaro  
*Deputy Director*

Kenneth Armwood  
Charles Kenny  
Leslie Koppel  
Shanti Narra  
Blanquita B. Valenti  
*Freeholders*

Shanti Narra  
*Chairperson, Public Safety and Health  
Committee*

John A. Pulomena  
*County Administrator*

Joseph W. Krisza  
*Department Head*

Michael Gallagher  
*Fire Marshal*

**COUNTY OF MIDDLESEX  
DEPARTMENT OF PUBLIC SAFETY AND HEALTH**


**Division of the Fire Marshal**

**DATE:** 10/07/2019  
**TO:** Borough of Middlesex Planning Board  
**FROM:** William Johnson, Deputy Fire Marshal, Middlesex County FM Office  
**RE:** **Application #**  
**Location: River Road / Baekeland Ave.**  
**Block: 353** **Lot: 1.01 & 1.02**

On behalf of the Middlesex County Fire Marshals Office, I have reviewed the above referenced plans and provide the following comments and concerns regarding the same.

**The Fire Marshals Office has no Comment on the Traffic Impact Study**

If you have any questions or need any additional information, please feel free to contact the Middlesex County Fire Marshals Office. 732-316-7194



Ronald G. Rios  
*Freeholder Director*

Charles E. Tomaro  
*Deputy Director*

Kenneth Armwood  
Charles Kenny  
Leslie Koppel  
Shanti Narra  
Blanquita B. Valenti  
*Freeholders*

Shanti Narra  
*Chairperson, Public Safety and Health  
Committee*

John A. Pulomena  
*County Administrator*

Joseph W. Krisza  
*Department Head*

Michael Gallagher  
*Fire Marshal*

**COUNTY OF MIDDLESEX  
DEPARTMENT OF PUBLIC SAFETY AND HEALTH**

**Division of the Fire Marshal**

**DATE:** 09/20/2019

**TO:** Borough of Middlesex Planning Board

**FROM:** William Johnson, Deputy Fire Marshal, Middlesex County FM Office

**RE:** **Application # P2019-05**

**Location: Middlesex LLC, River Road / Baekeland Ave.**

**Block: 353 Lot: 1.01 & 1.02**

On behalf of the Middlesex County Fire Marshals Office, I have reviewed the above referenced plans and provide the following comments and concerns regarding the same.

1. Have fire lanes and signs added to all non-parking areas and roadways around building.
2. Have knox box installed at fire department pump room and shown on drawings.

If you have any questions or need any additional information, please feel free to contact the Middlesex County Fire Marshals Office. 732-316-7194